

प्रजापति कृषि सहकारी संस्था लि

कनकाई, झापा

क्याटलग / ब्रोसर सपिङ विधिबाट खरिद सम्बन्धी सूचना

(प्रथम पटक प्रकाशित मिति: २०७७।०३।१३)

सार्वजनिक खरिद ऐन, २०६३ को दफा ८ को उपदफा १ (क ढ) तथा सार्वजनिक खरिद नियमावली २०६४ को नियम ३१ (ख) बमोजिम बाली संरक्षण भण्डार(कोल्ड च्याम्बर) उत्पादन गर्ने कम्पनी वा सो को आधिकारिक विक्रेताहरु बीच मात्र प्रतिस्पर्धा गराई क्याटलग सपिङ विधिबाट खरिद गर्नुपर्ने भएकोले इच्छुक ईजाजत प्राप्त उत्पादक कम्पनी वा सो को आधिकारिक विक्रेताहरुले आफ्नो फर्म नवीकरण समेत भएको दर्ता प्रमाण पत्र, मू.अ. कर दर्ता प्रमाण पत्र, र आ.व. २०७५।२०७६ सम्मको कर चुक्ताको प्रमाणित प्रतिलिपी समावेश गरी सार्वजनिक खरिद नियमावली, २०६४ को नियम ३१ (ख) को उपनियम (२) अनुसार देहाय बमोजिमको आधिकारिक विक्रेताले स्पेसिफिकेशन गुणस्तर, कम्पनिको मुल्य खुल्ने कागजात र सुविधा सहितको विवरण क्याटलग / ब्रोसर संलग्न गरि सूचना प्रकाशित भएको मितिले ७ (सात) दिन भित्र यस कार्यालयमा निवेदन दर्ता गर्नु हुन सम्बन्धित उत्पादक वा आधिकारिक विक्रेताको जानकारीकोलागि यो सूचना प्रकाशित गरिएको छ। निवेदन दर्ता गर्ने अन्तिम दिन बिदा परेमा त्यस पछि कार्यालय खुल्ने दिन दर्ता गर्न सकिनेछ। थप जानकारीका लागि कार्यालयमा सम्पर्क गर्नुहुन अनुरोध छ।

क्रम संख्या	आपूर्ति गर्नुपर्ने सामग्री	विवरण	अनुमानित ल ई रकम मु अ क सहित	परिमाण
१	बाली संरक्षण भण्डार(कोल्ड च्याम्बर)	Cold Room 25 ft x15 ft x10 ft 2 pcs with insulator Generator min 30 KVA (3 phase) with automatic panel system	रु ४५०००००।-	१(एक)

TECHNICAL SPECIFICATION OF COLD ROOM

S.n.	Particulars name	Offer Specifications
1	Cold Room Outer Size (Ft)	50' x 15' x 10' (W X D X H)
2	Cold Room Outer Size (Inch)	25' x 15' x 10' (W X D X H) - 2 No. Chamber
3	Room Internal Volume (in CFT)	7500 CFT
4	Total Storage Volume (Inner)	7000 C.F.T
5	Product	Fruits and Vegetables
1	Product Storage	60 MT (Approx)
6	Room Temperature	+4 degree C to +20 degree C
7	Product incoming Temp	+25 degree C to +30 degree C
8	Humidity Control	35% - 95%
9	Pull Down Time	24 Hr
10	Product Turn Over	10% of Total Storage
11	Man Occupancy	4 Person for 1 Hrs
12	Type Construction	Puf Panel with Outside & Inside PCGI Sheet with camlock arrangement.
13	Panel Thickness	80 mm. PUF Panel (poly urethane foam), Density 40 + 2 Kg / m3 Puf blowing agent
14	Panel Surface Material	80 mm. Puf Panel with Both side 0.5 MM - OUTER PCGI / INNER PCGI
15	Floor Insulation	80 MM puf slab for fixing of kota stone.
		Flush type Swing Door with Heavy duty Imported Hardware like Hinges, Handle & Door closer. Door frame made in Heavy duty PVC profile & Push type Gasket to stop air lose & easy operation for Long life.
16	Door Accessories	
17	Door Opening Size & Nos.	Door opening size : 34" x 78" (W x H) = 2 Nos.
18	Light	Vapour proof Bulk head provide proper lighting in each & every corner of the cold room.
19	Refrigeration System & Nos.	Split Type and 4 Number
20	Type of Condenser	Air Cooled
21	Type of Compressor	Hermetic Sealed Compressor
22	Compressor Make	Emerson/Danfoss
23	Total Connected Load	4 KW
24	Refrigeration Capacity	22,500 Btu each /Hr. x4 nos.



16.5
Mechanical Engineer

	(at -2 C Evap. & 50 C Cond.)	
25	Refrigerant	R-22/R407a
26	Evaporating Unit	Make ceiling Mounted Evaporating Unit and 4 Number
27	Capacity	4 KW, 12MTRS/CMH-4700M3/HOUR
28	DG Set Spec and Number	1 Set
	Genset Rating KVA	Minimum 30 KVA
	Noise Level	Silent or Soundproof
	Cooling System	Liquid Cooled (EG Compleat 50 Ratio 50)
	Frequency	50 Hz
	Control Pannel	Automatic Control Panel
29	warrenty	Two Years
30	Delivery	Prajapati Krishi sahakari sansthan Durga pur, Jhapa
31	MRP	4600000 With Vat



16.5
Mechanical Engineer